Ekorex – Consult, spol. s r.o. Company Identification No.: 47451394	User's Manual MAREG liquid level sensor	NKO0802/ BLZ
Na Lužci 657 Lázně Bohdaneč	Type BLZ-XX.XX	

User's manual approved on behalf of the manufacturer:	Date, stamp, signature
Petr Kohoutek - the Company Director	1.1.2017

This manual contains instructions, guidelines and pictures necessary for putting this device in operation and use, and for safe assembly, disassembly, maintenance, installation and adjustment.

This user's manual is supplied with each device.

Table of contents:

- 1. DESCRIPTION OF FUNCTIONALITY AND USE
- 2. DESCRIPTION
- 3. OPERATING CONDITIONS
- 4. TECHNICAL SPECIFICATIONS
- 5. OTHER INFORMATION
- 6. STORAGE, DELIVERY AND SHIPPING
- 7. INSTALLATION / ASSEMBLY, MECHANICAL ADJUSTMENTS AND START UP
- 8. ELECTRICAL ADJUSTMENTS, SERVICE AND REPAIRS
- 9. TABLE OF AVAILABLE MODELS
- **10. QUALITY GUARANTEE**

1. Functionality and use

1.1 Functionality

Limit switch Mareg consists of a head, pipe and float. The pipe is hermetically sealed in order to make sure that the inner space is separated from the liquid. The float moves freely on the pipe. The inner space of the device is closed with a screw-on lid equipped with a rubber o-ring. The pipe is fitted with magnetic limit sensors. Based on the level of the liquid the float moves on the pipe. The float uses magnetic field and sensor to indicated the liquid level. Up to four floats and four stopper rings may be used to measure the liquid level. As a default, the stopper has been set by the manufacturer a split second behind the time when the relay switches on. Number of sensors, placement as well as the level of output signal may be selected in the device order form. On the device questionnaire form it is necessary to specify the location of individual measuring locations and the direction from which the float will calculate and control the liquid level.

1.2 Product use

Mareg product types BLZ may be used for various measuring applications and step liquid level controlling procedures, offering up to two different levels. Based on the product type, you may use the device to control and measure liquids such as water, flammable liquids, acids, aggressive substances etc. High electric protection class (IP 65) allows the device to be used in harsh weather conditions. Based on a special agreement, the device may be fitted with a special sensor Pt100 and with a linear converter providing output between 4 and 20 mA.

You may use up to two stopper rings, two different floats (weight balanced) and also a combination of outputs "Open" - "Closed", which will allow you to use the device for other control and regulation processes. This combination may also be used to measure inter-levels. The manufacturer lends the float to a customer to test-measure the lower liquid level and based on the customer requirements the manufacturer produces a properly weight-balanced float, so it may be submerged and used to measure the lower liquid level. After this solution is applied, the user must take into account submerging of the float at the relevant interfacial tension line, changes in the density of the liquid, etc. The manufacturer

may also produce a float which may be gradually weight balanced (weight adding) at the measuring location (nonmagnetic ferrous metal must be used to add the weight to the float). In such scenario, the customer is for responsible for properties of such product (the manufacturer cannot affect changes in physical properties of the liquid - temperature changes, interfacial liquid tension, density and viscosity changes etc.).

The sleeve, guiding pipe and float contain mechanical components only and may be placed in zone 0. If required, you may use a model with a separate guiding/measuring pipe, which may be installed in the reservoir. The result evaluation head with terminals may be placed at a separate location, where the operating personnel may inspect the level of the liquid and control the activity of the device, etc. (cable is used to connect both parts).

The device may also be placed at the bottom section of the reservoir (measuring head facing downwards), and you may use auxiliary pipe for the measurement (the so-called "continuous container") and place the head of the device closer to the operator, offering better connection options and control of the technological process. You may use sleeve extension to bring the head out of the dip or out of the zone classified as explosion hazard. The lower section of the device may measure in environments classified as zone 0 and the head of the device with electronics and with intrinsic safety system may be used to measure in zone 1(2).

Thanks to high protection level, sensors are resistant against environmental changes in terms of humidity and are still able to perform measurements with high accuracy. The switch-on (closed status) spot is marked as h1 through h4 in the questionnaire. For liquid levels h1 through h2, the moment of switching is limited by the bottom line of the float magnetic field. Sensors do not remember previous statuses. When the float moves to a different level, the sensor goes back to its original mode. Sensors are very sensitive and are able to measurable levels with high precision and repeatability. After the probe of the reed relay switches on - when the float moves away from the previously measured liquid level, the probe is (due to the influence of magnetic field interruption) at least 50 mm away from its original position (based on the float type). Similarly, when the probe moves downwards, it is approximately (again due to the influence of magnetic field) 20 mm away from the previous level (based on the floor type). Therefore, it is necessary to account for this type of hysteresis during installation of sensors as well as during the actual measurement process.

2. Description

The sensor/limit switch consists of the following basic components:

Each device is equipped with a head, float and measuring pipe. Devices are fitted with a stainless steel guiding pipe / stem and a float. The head of the device is made of aluminium cast, which is attached with a stainless steel pipe. The pipe is sealed with a weld to make sure that the inner space is separated from the liquid. The float moves freely on the pipe. The inner space of the device is closed with a screw-on lid equipped with a rubber o-ring. The pipe is fitted with magnetic limit sensors. The float moves freely along the pipe - based on the level of the liquid, and uses magnetic field to indicate the level of the liquid.

2.1 Head of the device

The head is made of cast aluminium. Contacts and terminals are interconnected inside the head. Terminals allow you to make different type of connections. The device may be connected as switching terminal against common coupling or you may select four independent terminal connection method.

The head is usually available in two basic sizes/models. BVH080060 and BVH05045. The head complies with IP 65 protection class and the BVH080060 head is fitted with a standard lid (aluminium cast piece with a rubber seal and lid) and complies with protection class IP 65.

The device may also be fitted with a converter providing electronic output (4 to 20 mA – information about the liquid level are provided in incremental steps - in mA). The device may also be fitted with passive components such as the Pt 100 sensor, linear converter providing output for Pt100 or with other components based on customer requirements (special model/design).

2.2 Guiding pipe

The guiding pipe is made of stainless steel. The guiding pipe (commonly referred to as "guiding rod") is closed at the bottom and separates the inner part of the device from the liquid. The pipe may also be used in pressurized vessels up to 1,6 MPa. Maximum length of a stainless steel pipe is 2,000 mm. Up to the length of 2,000 mm, the pipe outer diameter is usually 10 mm. Based on the filling method, or if you have to deal with turbulent fluid level, we recommend using a pipe starting at 1,000 mm in length. The

guiding rod may also be fitted with a collar only (low-height type - cannot be used in pressurised vessels).

A rod attached with probes is inserted inside the pipe. During adjustments or inspection you may remove the rod with probes from the pipe. Probes may be moved along the rod up.

2.3 Sleeve

It is a connection member fitted with a threading or collar and rotating flange. The flange allows the guiding pipe to be attached to the bottleneck of the reservoir, and at the same time, it allows the device to be turned to suitable position for installation. The flange may be type DN50 PN16 according to ČSN 13 11 60. For pressurized reservoirs you may use sleeve DN50 PN40 with a collar fitted with a tongue and groove. The size of the collar is usually 60 mm.

2.32 In certain cases we may also offer sleeves up to maximum of 500 mm (allowing the sleeve to be submerged in liquid, low-set reservoir, head placement in a separate room with lower explosion hazard, high temperature in the reservoir, etc.). Special design is done after agreement with the manufacturer (equipment, float, etc.).

Clamping, welded thread fitting and assembled flange is designed to be attached to the lid of the reservoir and it is included in the delivery - based on agreement with the customer. Clamping thread fitting allows the pipe to move freely along its entire length and to turn the head of the device as required. Clamping flange is not suitable for pressurized vessels. Rubber o-ring is placed between the pipe and the inner wall of the clamping fitting to provide seal and to prevent vapours from escaping.

2.4 Float

- 2.41 The manufacturer offers different types of floats for different liquid densities. Floats types BZP130160 and BZP071083 are used for pipe diameters between 10 mm and 2,000 mm. The first three numbers in the label code represent the diameter of the float, and the following numbers represent the height of the float and the float pipe. If agreed with the customer, the device may also be used to regulate inter-levels or highly viscous liquids, provided that different floating device is used.
- 2.42 Up to four floats and four stopper rings may be used for measurements. As a default, the stopper has been set by the manufacturer a split second behind the time when the relay switches on.
- 2.43 Specially designed devices may be used to measure high density and high viscosity liquids. These types of devices are fitted with fixed floating device. The float is attached to a moving arm and does not move along the guiding rod. Device fitted with a float attached to a moving arm may be installed in various positions on its side, at the bottom, or it may be used for top measurements. Another special model with a fixed pipe may also be used to measure viscous liquids. Both types offer option to remove extension pieces. Sediments deposited by viscous liquids may be easily removed from the extension piece, or the entire extension may be replaced.

3. Operational conditions

- 3.1 Operational conditions
- 3.11 The design of the device provides safe use and operation in environments specified in:
- a) cold environments
- b) hot environments
- c) zone 0 (pipe and float) zone 1, zone 2 /for certain device types connection head/
- e) dusty environments
- f) wet environments

3.12 Safety class IP65

3.13 Atmospheric pressure around the device head 86 to 106 kPa

3.14 Measured liquid/media: density 0.55 to 4 (xx) kg.m⁻³

3.15 Operating overpressure at the measuring point

-stainless steel maximum 1.6 MPa

If the float is not designed for this type of pressure, it is necessary to place it outside of the reservoir during testing

3.16 Ambient temperature

Temperature of the measured liquid/medium -30 °C to +100 °C

Temperature at the measuring location T4

Designed to be used in explosive environments

3.17 Working position horizontal

3.18 Special design – working position is perpendicular to the head in bottom

position permanent

3.19 Type of operation

4. Technical specifications

4.1 Measuring range - stainless steel design max. 2,000 mm

4.2 Insensibility ± 5 mm

4.3 Maximum switching voltage max.40V AC/DC/100 mA

(each contact)

4.4 Basic error $\pm 1 \text{ mm}$ 4.5 Additional errors $0.02 \% /1^{\circ}C$ 4.6 Insulation resistance 10^{10} Ohms 4.7 Switching speed0.2 ms

b) Service life

5 V DC, 10 mA 5×10^7 10 V DC, 100 mA 10^7 50 V AC 5×10^7

Note: – when evaluating output signal, repeated inaccuracies may be compensated for by the control system.

5. Other information

5.1 Type of operation permanent

5.3 Device label

5.31 Manufacturer label (located on the cast head):

a) manufacturer identification, including address
 b) device type BLZ-XX.XX.XX
 c) year of manufacture for example 2002
 d) serial number Serial No.

- e) manufacturer specifications country of origin Made in Czech republic
- c) General label (located on the rear lid or on the machine side):
- a) manufacturer reference number Technical documentation file No. NKO0802/ BLZ (valid User's manual)
- d) Label necessary due to safety reasons Temperature range T4
- e) General label may contain other necessary information for example a wiring diagram, information about built-in components, etc.

General label usually contains the following basic information:

6. Storage, delivery and shipping

6.1 Storage

The device may be stored in temperature range from -20 $^{\circ}$ C to +40 $^{\circ}$ C, with maximum relative humidity of the surrounding air 75 %.

6.2 Delivery

The device is delivered with the following documentation: NKO0802 / BLZ Ex User's manual including applicable annexes or with additional documentation if agreed between the manufacturer and customer. 6.3 Transport and storage

Products are delivered in packaging which provides sufficient stability and protection against mechanical and temperature variations.

The device is shipped as follows:

After assembly and final inspection, the float is attached to the guiding pipe.

The device is shipped in a packaging unit fitted with a label specifying the manufacturer and the customer.

6.4 Recycling

Each device may be separated based on individual material types and as required by Waste management regulations SM - 15 and therefore, it can be safely stored or disposed of.

7. Installation / disassembly, mechanical adjustments and startup

7.1. Assembly, startup, operation and use, service

Installation of limiting devices is done by the manufacturer or by other companies authorized by the manufacturer to do so. Due to the simplicity of the device, other professional companies may also perform the installation.

- 7.2 In general, the device does not require any operations or maintenance. However, the manufacturer recommends to perform inspection of the device and its configuration settings after 2 or 5 years of operation. This shall depend on operational conditions aggressive environment, vibration etc.. The device is not equipped with its own fuse or switch.
- 7.3 Repairs are done by the manufacturer. The device is removed and applicable inspection of the device and its configuration is performed.
- 7.4 The manufacturer reserves its right to change technical parameters at any time
- 7.5 Service and installation is done by the manufacturer or by a company authorized by the manufacturer to do so. The list of servicing companies as well as installation or maintenance could be agreed directly at the company headquarters.

8. Electrical adjustments, service and repairs

- 1.1 Installation and adjustment of electrical components is rather simple, and it is done by the manufacturer or by other companies authorized by the manufacturer to do so. Due to the simplicity of the device, other professional companies may also perform the installation. The switching level has been preconfigured based on parameters specified in the order form.
- 1.2 The manufacturer reserves its right to change technical parameters at any time
- 1.3 Service and installation is done by the manufacturer or by a company authorized by the manufacturer to do so. The list of servicing companies as well as installation or maintenance could be agreed directly at the company headquarters.
- 1.31 Regular inspection and maintenance (approximately after one year of operation) In general, we inspect whether the readout on the visual display, the output signal and measured values match (for example measured by the measuring pipe).
- 8.42 Basic maintenance (approximately after 5 years of operation)

We inspect whether the status of the measured medium and the output signal matches values measured by the measuring pipe. Based on the recommended service life and based on conditions where the device operates, we select the proper maintenance.

8.43 Midterm device repair (approximately after 7 years of operation)

Midterm repairs are done by the manufacturer. The device is removed and all components are inspected. Screws and screw couplings are lubricated, switches are replaced, seals and transmitting device are inspected. All seals are replaced.

8.44 Service life and maintenance (based on individual needs and spring service life)

Based on the environment where the device operates (humidity, acid vapours, gases, sudden weather changes, or changes in the surrounding environment, vibrations, spring life service, etc.) we will select the basic maintenance interval. If the device is used in harsh environment, with recommend at least one midterm service per year (applies to the above specified environments). If the device is used very often, the maintenance interval is based on the maximum life expectancy of relevant switches.

8.45 Complete repair/rebuild and device component update, etc.

We recommend complete repair / rebuild and update of device components (possible thanks to modular design of the device) done at the manufacture facility because the operation could be completed during one day and delivered back to customer (depends on the status of the device and on the scope of the repair).

8.46 Installation of the device is done by the manufacturer or by other companies authorized by the manufacturer to do so. Repairs are done exclusively by the manufacturer.

Should the customer attempt repairs, he may lose warranty and the manufacturer will not guarantee save operation.

- 8.5 The manufacturer reserves its right to change technical parameters at any time
- 8.6 Service and installation is done by the manufacturer or by a company authorized by the manufacturer to do so. The list of servicing companies as well as installation or maintenance could be agreed directly at the company headquarters.

9. Table of available models of liquid level sensor BLZ-XX.XX.XX

See Annex NKO0802/BLZ

10. Quality guarantee

- 10.1 The manufacturer guarantees the device for 12 months, as required by the Commercial Code (paragraph 429 et seq.). Defects occurred during the warranty period due to clearly defective material or workmanship will be repaired for free, provided that the device is sent back to the manufacturer in its original or suitable packaging. If the repair is done at the customer facility, the manufacturer will charge for the travel cost and repair time according to valid price list of the manufacturer.
- 10.2 Warranty does not cover defects caused by unauthorized tempering with the device, by failure to comply with technical and operational requirements specified by the manufacturer, by forced mechanical damage and incorrect installation procedures. Further, the warranty does not cover defects due to incorrect installation process done by unauthorized installation company.
- 10.3 The manufacturer reserves its right to change the product design or to make changes in the product documentation. Any modifications will be attached in a form of a Annex to the applicable product documentation.

Manufacturer address: Ekorex-Consult, spol. s r.o.

Na Lužci 657

533 41 Lázně Bohdaneč

Czech republic

Phone/Fax: +420 466 921 078 E-mail: ekorex@ekorex.cz